


Environmental Working Group

Monthly Report

November 2012

ENVIRONMENTAL WORKING GROUP Relationship Organizational Chart



- Weekly Environmental Working Group (EWG) and EWG/Kiewit Alarie, a Partnership (KAP) meetings.
 - The EWG review its Action Items that include priority permit reviews, and deliverables to the Mattagami Extensions Coordinating Committee (MECC).
 - ▶ KAP gives EWG a construction up date every week and discusses any upcoming issues and/or urgent permit reviews.
 - Specific items that were discussed are below.
- Inclusion of a First Nation perspective on the Cost Benefit Analysis of Mitigating and Reducing Spill in Adam Creek. TTN and MCFN have completed their interviews and continue to look at ways to incorporate the First Nation perspective within the report. MCFN presented summary of the Cost Benefits TEK study to the MECC in October.
- MCFN and TTN members of the EWG hold weekly Traditional Ecological Knowledge (TEK) meetings to develop TEK monitoring plan as component of Environmental Effects Monitoring Plan and to address term and condition 13 Aboriginal Knowledge.
- Review and collection of baseline reports intended to fulfill EA Term and Condition 4b is ongoing.
- Reviews of the Terrestrial Habitat Restoration Downstream of Kipling report intended to fulfill EA Term and Condition 5b is ongoing. The report is being amended to include the comments received to date from OPG and TTN on the report. As part of the EWG review process, the Hatch authors will present their work to the EWG as soon as possible.
- Members of the EWG continued their work on the "Peoples of the Moose River Basin" historical text (EA Term and Condition 2c). Several members of the EWG have begun writing portions of the text. Access to review progress on the book, which is posted on a private blog, was offered to the MECC in October.
- Hatch members of the EWG have been incorporating comments on the final draft of the EWG Environmental Due Diligence Audit held in July 2012.
- On November 14 and 15, 2012, the EWG held a two day workshop to determine what baseline parameters are required for the baseline/monitoring EA Terms and Conditions, and how can TEK be taken into consideration within these conditions. The workshop was facilitated by LURA Consulting (EWG Team Building), and in addition to the members of the EWG (including Hatch) the workshop included MECC Experts Larry Onisto and Alex Litvinov, OPG Fisheries Biologist Dan Gibson, and TEK experts Richard Preston and Paul Wilkinson. Overall the workshop was successful in achieving its objectives.
- The EWG presented the results of the baseline and TEK workshop to the MECC, and the MECC accepted the recommendation. The EWG has started work on collecting additional baseline information and implementing the recommendations to incorporate TEK within the Baseline/monitoring EA Terms and Conditions.

ACTIONS TO BE COMPLETED in 2012

	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec
EA Terms and Conditions Environmental Compliance Plan – EWG Review and												
Submission to MECC.												

	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec
EWG Environnemental Due Diligence Audit #2												
EWG present to the MECC the result of its review of the LMRP "Operations												
Report" (Condition 4(a) of EA T&Cs).												
EWG present to the MECC the result of its review of the "Fish Habitat												
Assessment Report", and "Baseline Fish Methyl Mercury Report" (Condition 4b												
of EA T&Cs) by Hatch*.												
EWG present to the MECC the result of its review of the draft "Cost Benefit												TBD
Analysis of Mitigating and Reducing Adam Creek Spill" (Condition 4(c) and (e) of												
EA T&Cs) by Hatch.												
EWG present to the MECC the "Waste Management Plan" (EA T&C 19).												
EWG present to the MECC "The Noise Protocol Plan" (Condition 18 of EA T&Cs).												
EWG present to the MECC "Environmental Monitoring Plan, Lower Mattagami												TBD
Development" (EA T&C 14).												
EWG present to the MECC the "Erosion Monitoring Plan" (EA T&C 6).												TBD
EWG present to the MECC the "Evaluation of the Need to Conduct Terrestrial												
Habitat Restoration Downstream of Kipling" (EA T&C 5)*.												
Draft of Traditional Ecological Knowledge in relation to the Lower Mattagami												
River Project*.												
EWG present to the MECC the results and recommendations of periodic re-												TBD
evaluations (Condition 10 of EA T&Cs).												
Completed: Pending: *Additional work still requir	ed to f	ulfill E/	A Term	and C	onditio	n						

Construction

Little Long

- As noted last month concrete work is nearing completion, with only small pours remaining to complete that phase of the work. 4 m³ of concrete was poured this month, bringing the total poured to date to 13,267 m³ of 13,886 m³ total, against a plan of 13,611 m³.
- The foam insulation and outer cladding installation are complete for both the north and east walls of the powerhouse (Figure 1). Canam continues to waterproof the Unit 3 powerhouse roof.
- Adjustments to and the survey of the bottom ring / discharge ring / draft tube liner assembly is complete. The final survey has confirmed that the assembly meets the required specifications.
- KAP workers have completed the erection of the formwork required for the secondary concrete to be poured in the area between the bottom of the draft tube liner and the bottom part of the stay ring. All rebar and tie anchors have been installed and the pour is scheduled for early December.
- AFI workers have completed the installation of the intake gate roller path and side guides. They are also working on the erection of the draft tube gate hoist superstructure on the Unit 3 tailrace deck.
- KAP electricians have completed the installation of the three superimposed cable trays required for the 13.8 kV Unit 3 power cables, and 600 V and 125 V DC distribution cables.
- Subcontractor Northern Fencing has installed the fence around the new switchyard.
- Removal of the cofferdam continues. All blasting to remove Cell 2 and Cell 3 tremie concrete is complete and clamming of the blasted concrete is under way. Cell 2 spud pile removal is nearing completion. The template for Cell 1 removal has been partially assembled on the barge.



Harmon

- 1,132 m³ of concrete was poured this month, bringing the total poured to date to 10,227 m3 of 12,251 m3 total, against a plan of 8,787 m³.
- KAP has completed concrete repairs on the West wall of the penstock. Scaffolding is being relocated to the East wall for repairs there.
- The first scroll case soffit pour was completed (1,103 m³). Formwork, embedded piping, shoring tower, and rebar installation for the second scroll case soffit is advancing. The second soffit pour is planned for December 1st (Figure 2).

- Andritz have mobilized the self-leveling milling machine required for machining the stay ring. Staff required for that activity will be arriving on site in December. Scaffolding was erected in the draft tube to support the stay ring machining operation.
- A temporary insulated wall and other winter measures were put in place in the existing south gallery of the powerhouse to protect existing utilities. This was required to remove the block wall required for the extension of the gallery. Once the winter measures were put in place, the demolition of the block wall was completed.



Kipling

Figure 2: Harmon Generator Floor Pour

- 1,109 m³ of structural concrete was poured this month, bringing the total poured to date to 4,294 m³ of 11,647 m³ total, against a baseline plan of 8,500 m³.
- As the volume number indicates above, several large concrete pours were completed in the month. Rebar and formwork are under way for the next large powerhouse pour (Figure 3).
- Backfilling and landscaping in the switchyard continues.
- Installation of the new 15 kV bus bars continues.
- A joint walkdown between OPG/Hatch and KAP was held prior to testing the station disconnect switch and the stand-alone switch, and several items were added to the testing punch list. The new switch is planned to be transferred to OPG on December 13th. This activity is required to connect the existing units to the new Hydro One 230 kV circuit.



Figure 3: Kipling Powerhouse Overview

Smoky Falls

- 5,943 m³ of concrete was poured this month in the service bay, powerhouse, and intake areas, bringing the total poured to date to 81,124 m³ of 155,084 m³ total, against a plan of 81,930 m³.
- At the end of the month, fifteen (15) concrete pours are in various stages of work (formwork started and/or rebar being installed) and progressing in the intake, powerhouse, East gravity dam (Figure 4), and at the permanent bridge. Twenty six (26) pours were completed during the month.
- Alstom has welded the anchors on the draft tube cone at Unit 1, and are fitting and welding the lower pit liner to the stay ring.
- Alstom also successfully completed the welding of the Unit 2 draft tube cone, and follow-up quality inspections revealed no welding defects.
- In the switchyard, drain piping was installed and backfilling was completed. Valard electricians are working on terminating the control wiring for the disconnect switches and the high voltage wiring for the current transformers.
- The steel superstructure erection over the Service Bay West is now enclosed and heated. Supermétal workers are now working at erecting the superstructure over Units 1 and 2 and the station tailrace deck.
- Some operational testing of the 275-ton Kone crane was completed and a partial load test was successful, allowing KAP to turn over the crane to Alstom for their use in the service bay for assembly of stay rings, draft tube cones and other turbine embedded components.
- Sluiceway Gate 5 A crack was identified in the east pier concrete. Rivard Engineering has provided a report and a repair method to KAP. AFI has started installing anchors for the new hoist control building.
- Valard has completed installing insulators and travelers on the tower structures. They are stringing cables between structures #6 and #15 of the transmission line. Dead-ends were installed at structure #15. Travelers were installed in preparation for stringing the transmission line between structures #6 and #4.



Figure 4: Smoky Falls Overview including Superstructure

SPILL	S								
	f Spills:	6: Spill	Reports	297-302 (see Figure 6 for LMRP spills breakdown).					
	Classification of Project Classification								
Spills				lerate – 2 Major –1 To Water - 0					
Spins	•			-					
		MOE Classification Non-reportable - 4							
			able to N						
			_	Class C – 2					
			-	Class B – O					
			-	Class A – 0					
· · ·	rtable Spill								
No.	Quantity /Product Sp	Spill Sit	e	Reason for being Reportable					
	Sewage/78	=		Reportable (due to quality and quantity). A routine check of the					
	L	Main Ca	•	waste water treatment plant by camp maintenance identified a					
		Waste \ Treatmo		large pool of water on the pad and noticed it was coming from the pump lift station. It was determined that although the high					
		Plant	ent	level alarm did function the level switch for the pump did not					
1		i lunc		activate the pump. An audible alarm and light will be installed					
				that will be triggered once the high level alarm is activated. An					
				automated dialer will also be installed to notify the plant					
				operator, OCWA, in the event of a high level alarm. KAP					
		Electrical Department will investigate the cause of the electric							
	Cituia		malfunction and replace circuit board if required.						
				Reportable (due to quantity). The valve on the citric acid tote located next to the sediment pond was observed to be					
	10 - 20L	Sedime	leaking/spraying acid onto the ground. The valve and						
2				the tote was replaced with a new one and the secondary					
				containment was adjusted to ensure the valve was underneath					
				the containment.					
Proje	ct Classifica	ation (KAP)		MOE Classification					
-	Minor: ≤ 10L			Non-reportable: < 100L					
		veen 10L and	100L	Reportable to MOE					
Major: ≥100L				Class C - Less Serious					
	To Water: Any amount is reportable			Class B – Serious					
• Class A – Very Serious				Class A – Very Serious					
-	-	AP Spills Resp	onse						
Flow	,	F	(= ()						
		Exceedance	of Effluer	•					
	lo. of	Location		Mitigation Measures used					
	eedance								
aays	recorded	Cupa a lui i	On No	and an E. 2012 indicated that the Creative E-line and increase					
	1	Smoky		ember 5, 2012 indicated that the Smoky Falls sediment					
(N	(Nov. 5) Falls pond was slightly above the 30 NTU objective with a reading of 30								
				he increase in turbidity was the result of large amounts of					
			rain.						

Monthly Summary – November 2012

2 (Oct. 29*, Nov. 12)	Kipling	Samples collected on Oct 29 for the Kipling sediment pond were above the 15mg/L effluent objective and the 25 mg/L effluent limit, with a reading of 55mg/L. The increase was due to the washing out of the ditch which the sediment pond was discharging into. On
*This was not reported until Nov.		October 29, 2012 the discharge pipe was extended to the river and by the afternoon the sediment pond was directly discharging to the river. Notification was made on Nov 4.
		On November 12, the pH levels were above the C of A effluent objective $(6.5 - 8.5)$, with a reading of 8.84pH. KAP added citric acid to the pond as a corrective measure to help decrease the pH levels. The increase in pH level was a result of the washing of the green-cut that occurred during the night and early this morning.

KAP:








Figure 7: KAP Spills Response Flowchart


PERMIT AND APPI	ROVAL REVIEV	V	
No. Reviewed:	0	List:	
No. Sent to KAP:	0	List:	
Reports Review			
No. Reviewed for KAP	0	List:	
No. Sent to KAP	0	List:	
No. Reviewed for MECC	5	List:	 On-going: Cost Benefit Analysis of Mitigating and Reducing Spill in Adam Creek. Mercury in Fish Flesh Summary Report. Fish Habitat Assessment Report Terrestrial Habitat Restoration Downstream of Kipling GS
No. Review Completed	4	List:	 Operation Overview Report. Waste Management Plan Noise Control Plan The Interim Measures Agreement as it relates to EA Term and Condition 14c (Permit Review and Compliance Monitoring Protocol)
REQUESTS FOR IN	FORMATION (RFIs)	
No. Reviewed:	0	List:	n/a
No. Sent to KAP:	0	List:	n/a
See figures 8 to 13	below for site	location of the	e permits that have been or are pending approval.














15 | P a g e

Issues and Concerns
 During the Baseline/TEK Workshop held in November 2012, concerns were brought forth by MCFN and TTN members of the EWG regarding the inadequate incorporation of TEK within the LMRP. The underlying issue was that the baseline studies were designed without FN input as was directed by the EA terms and conditions. The workshop resulted in all EWG members acknowledging this problem and identifying the need to conduct additional extensive studies which were identified, as well as focussed workshops with the First Nations on various terms and conditions and the need to improve the EWG understanding of TEK. Additional baseline parameters were identified for the baseline/monitoring EA Terms and Conditions, and recommendations were brought forward on how TEK can be taken into consideration within these conditions.
Action: Implement the recommendations from the Baseline/TEK workshon held in

Action: Implement the recommendations from the Baseline/TEK workshop held in November 2012, and continue to pursue ways to incorporate TEK within studies, monitoring and other activities in relation to the LMRP (ex. additional workshops).